



EXCHANGER SIZE *—BAFFLE SPACING	DIMENSIONS											
	A		B		C		D		N1		N2	
	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm
W3H-42-2*-4	33 5/8	848	16 1/2	419	9 3/4	254	26	660	2	51	2	51
W3H-43-2*-4	45 5/8	1153	28 1/2	724	21 3/4	559	38	965	2	51	2	51
W3H-44-2*-4	57 5/8	1458	40 1/2	1029	33 3/4	864	50	1270	2	51	2	51
W3H-45-2*-4	69 5/8	1762	52 1/2	1334	45 3/4	1169	62	1575	2	51	2	51
W3H-46-2*-4	81 5/8	2067	64 1/2	1638	57 3/4	1473	74	1879	2	51	2	51
W3H-47-2*-4	93 5/8	2372	76 1/2	1943	69 3/4	1778	86	2184	2	51	2	51
W3H-48-2*-4	105 5/8	2677	88 1/2	2248	81 3/4	2083	98	2489	2	51	2	51
W3H-49-2*-4	117 5/8	2982	100 1/2	2553	93 3/4	2388	110	2794	2	51	2	51
W3H-410-2*-4	129 5/8	3286	112 1/2	2858	105 3/4	2693	122	3099	2	51	2	51

NOZZLE SCHEDULE				
SERVICE	MARK	SHELL SIDE	MARK	TUBE SIDE
INLET	N1	AS PER TABLE	N5	1 1/4 (32) 300# FLG.
OUTLET	N2	AS PER TABLE	N6	1 1/4 (32) 300# FLG.
DRAIN	N3	1/2 (13) NPT		
VENT	N4	3/4 (19) NPT		

NOTES: 1. SUPPORTS SUPPLIED ONLY IF SPECIFIED ON ORDER.
 2. NOZZLE SIZES SHOWN ARE RECOMMENDED FOR MAXIMUM EXCHANGER LIFE.
 3. FABRICATED TO ASME CODE SECTION VIII DIVISION 1 AND LATEST ADDENDA.
 4. DRAWING IS NOT TO SCALE.
 5. ALL DIM'S ±1/8 (3) UNLESS OTHERWISE SHOWN.

DESIGN CONDITIONS				
	SHELL		TUBES	
DESIGN PRESSURE	300 PSIG	2068 KPa	300 PSIG	2068 KPa
DESIGN TEMPERATURE	375 °F	191 °C	375 °F	191 °C
MIN. DESIGN METAL TEMP.	35 °F	1.7 °C	35 °F	1.7 °C
HYDRO. TEST PRESSURE	450 PSIG	3102 KPa	450 PSIG	3102 KPa
CONTENTS	WATER		WATER	

CUSTOMER: _____
 LOCATION: _____
 ENGINEER: _____
 ORDER No.: _____
 PROJECT/JOB: _____
 LOCATION: _____
 TAG: _____ (QUOTE # _____)

TITLE: G.A. 300 LB. W SERIES HEAT EXCHANGERS	A R M S T R O N G				NUMBER: W3H-4-2P-4(2)	REV: _____
DATE: 11 / 09 / 00 BY: J.R.	TORONTO - CANADA TEL: (416) 755-2291	MONTREAL - CANADA TEL: (514) 421-2424	BUFFALO - N. Y. TEL: (716) 693-8813	COLDHESTER - U.K. TEL: (44) 120-657-9491		